


STC
54

IIC
45

Assembly

- Concrete Slab, 2-3/4" (70mm)
- Sonus Curve 25, 1" (25mm)
- Glulam Decking, 3-1/2" (89mm)



Contact

REGUPOL America LLC
11 Ritter Way
Lebanon, Pennsylvania 17042
UNITED STATES OF AMERICA
www.regupol.com

Notes

Adjacent trades are only shown schematically and in parts. The applicability and other conditions or constraints need to be checked by the consumer of user on their own responsibility. The technical data sheets, installation instructions and local conditions need to be considered.

Acoustical Test Assembly

Test Report no.: A1-008253-14F

Test Report no.:

Drawn by: DLG

Test Date: 2.25.2016

Scale: N/A DWG no.: 1