


STC 62	IIC 53	Δ IIC 25	Rw 61	Lnw 57	Δ Lnw 21
-----------	-----------	--------------------	----------	-----------	--------------------

Assembly

- Concrete Slab, 3-15/16" (100mm)
- Sonus Curve 8, 5/16" (8mm)
- Concrete Slab, 5-1/2" (140mm)



Contact

REGUPOL America LLC
11 Ritter Way
Lebanon, Pennsylvania 17042
UNITED STATES OF AMERICA
www.regupol.com

Notes

Adjacent trades are only shown schematically and in parts. The applicability and other conditions or constraints need to be checked by the customer or user on their own responsibility. The technical data sheets, installation instructions and local conditions need to be considered.

Acoustical Test Assembly

Test Report no.: DP-024-H418-42823_E
Test Report no.: DP-024-H417-42823_E
Drawn by: DLG
Test Date: 3.29.2017
Scale: N/A DWG no.: 1