


STC
57

IIC
54

Assembly

- Engineered Hardwood, 3/8" (9mm)
- Sonus Curve 6, 1/4" (6mm)
- Magnesium Board, 3/4" (19mm)
- Steel C-Joist, 10" (254mm)
- SonusClip Ceiling



Contact

REGUPOL America LLC
11 Ritter Way
Lebanon, Pennsylvania 17042
UNITED STATES OF AMERICA
www.regupol.com

Notes

Adjacent trades are only shown schematically and in parts. The applicability and other conditions or constraints need to be checked by the constomer of user on their own responsibility. The technical data sheets, installation instructions and local conditions need to be considered.

Acoustical Test Assembly

Test Report no.: J8051.10-113-11-R0
Test Report no.:
Drawn by: DLG
Test Date: 6.24.2019
Scale: N/A DWG no.: 1